

# PIONEER PROJECT SOLUTION

## HVAC Design & Built Contractors

Registered Office : 12A/20B, Gali No. 10, Vijay Mohallah, Maujpur, Delhi-110053

Tel.: 9810634901 Website : www.pioneerprojects.in Email : projectspioneer@gmail.com

Branch : E-93-B, First Floor, Shaheen Bagh, Abul Fazal Enclave-II, Jamia Nagar, Okhla, New Delhi-110025

TAX INVOICE							
Order No	TFSP/PO/24-25/000402	GST No.	07AHQPA6815Q2ZQ				
Invoice Date	20/11/2024	Pan No.	AHQPA6815Q				
Invoice No	376-2024-25	Client Detail					
Client Name	Travel Food Services Pvt. Ltd	GST No.	07AADCB2762LZLZ				
Project	FIRE Sprinkler WORK	C.I.N.	NEW Terminal - 1, Indra Gandhi International Airport, Domestic Departure SHA, Mehram Nagar, New Delhi, New Delhi, Delhi - 110037.				
Delivery Add	Fire Work Delhi T-1, Dominas	Billing Address					
ITEM CODE	ITEM NAME	HSN Code	UOM	QTY	UNIT COST	AMOUNT As Per WO	80 % Running Bill Amount
<b>FIRE SPRINKLER SYSTEM</b>							
<b>AUTOMATIC PIPE SPRINKLER HEADS &amp; ACCESSORIES</b>							
A.1	Supply, Installation, Testing & Commissioning of Automatic Concealed Fire Sprinkler Heads (Quick Response) (Bulb type Sprinklers) with adjustable Escutcheon plates (Rosette plates), Standard Temperature Response with 5mm glass bulb, Temperature rating of 68° C, K-factor of						
A.1.1	Concealed Pendant type of 68° C (Chrome Finish Plate Cover)	8424	Nos	8	2250	18000	14400
A.1.2	Concealed Pendant type of 79° C (Chrome Finish Plate Cover)	8424	Nos	2	2450	4900	3920
A.2	Supply, Installation, Testing & Commissioning of Automatic Fire Sprinkler Heads (Quick Response) (Bulb type Sprinklers) with Standard Temperature Response with 5mm glass bulb, Temperature rating of 68° C / 93° C, K-factor of 80, Nominal Thread size of 1/2" NPT (15mm) and a Orifice size of 13mm with a Max. Working Pressure of 12 Bar (Factory hydrostatic test) pressure of 35 Bar) and to be Manufactured & Certified to UL 199. It shall also include suspending arrangements with ceiling/wall etc.						
A.2.1	Upright type of 68° C (Finishing - Chrome Plated)		Nos	0	1450	0	
<b>FIRE SPRINKLER PIPE VALVES &amp; ACCESSORIES</b>							
A.3	Supply, Installation, Testing & Commissioning of Cast Iron Butterfly Valve slimseal PN16 (working pressure of 16 Bar), standard flow control lever operated with stainless steel shaft & disc, seal material with Black Nitrile / EPDM, flanges nuts and bolts etc.						
A.3.1	65 mm Dia	8481	Nos	1	5500	5500	4400
A.4	Supply, Installation, Testing & Commissioning of Brass body Test And Drain Valve with Sight Glass, working pressure of 20 Bar (300 PSI), standard lever operated with stainless steel stem & lever, with necessary weldable fittings in position as per drawings / site conditions.						
A.4.1	25 mm Dia	8481	Nos	1	700	700	560
A.5	Supply, Installation, Testing & Commissioning of Flow Switch on Sprinkler distribution header pipe with a working pressure of 31 Bar (450 PSI) and a flow sensitivity range of 4-10 GPM (15 - 38 LPM) on each floor / zone / Inside proposed demise area tap of point, shall be connected to fire alarm panel through cable.						
A.5.1	65 mm Dia		Nos	0	5500	0	
<b>FIRE SPRINKLER PIPING</b>							
A.6	Supply, Installation, Testing & Commissioning of GI "C" Class Fire Sprinkler Pipe conforming to IS: 1239 with all fittings like bends, tees, flanges, nut, bolt and washers etc. and proper pipe supports to not more than 3 meter apart of the pipe length. The pipe work shall be hydrostatically tested for not less than 2 hours at 15 Bar (or 1.5 times the working) pressure without leak. The pipes are to be applied with 2 coats of primer (indicated film thickness, dry 50 microns) and 2 coats of enamel (finish point of approved colour (indicated film thickness, dry 30 microns)						
A.6.1	25 mm Dia	7306	Mtr	37	700	25900	20720
A.6.2	40 mm Dia	7306	Mtr	18	1000	18000	14400
A.6.3	50 mm Dia	7306	Mtr	12	1200	14400	11520
A.6.4	65 mm Dia	7306	Mtr	5	1350	6750	5400
<b>SPRINKLERS BRAIDED FLEXIBLE PIPE</b>							
A.7	Providing & fixing testing and commissioning of UL Rated Braided SS Flexible pipe (Assumed required at site) 1500 MM LONG	3917	No.	10	2500	25000	20000
<b>TOTAL</b>						119160	95320
CGST@9%							8579
SGST@9%							8579
<b>GRAND TOTAL</b>							112478

For Pioneer Project Solution

Auth Signatory



*Handwritten signature and date: 29/11/24*

*all to process for up to 70% payments. Main invoice 28/11/2024 final bill to be submit along with (MS) documents*

*80% work completed*

*Handwritten signature and date: 21/11/24*

# Purchase Order

## TRAVEL FOOD SERVICES PRIVATE LIMITED

Order Number : TFSPL/PO/24-25/000402

<b>Supplier Detail</b> PIONEER PROJECT SOLUTION Supplier Code : RV232414136 [ V0002345 ] (V0002345)	<b>Shipped Location</b> TRAVEL FOOD SERVICES PRIVATE LIMITED Delhi New Terminal 1, Indira Gandhi International Airport, Domestic Departure SHA, Mehram Nagar, New Delhi, New Delhi, Delhi, 110037	<b>Invoice Location</b> TRAVEL FOOD SERVICES PRIVATE LIMITED Delhi New Terminal 1, Indira Gandhi International Airport, Domestic Departure Sha, Mehram Nagar, New Delhi, New Delhi, Delhi, 110037 GSTIN No : 07AADCB2762L2ZJ
PAN No : AHQPA6815Q Supplier GST No : 07AHQPA6815Q2ZQ Supplier Contact No : Contact Person Name : Mohd Ashraf Supplier Email : projectspioneer@gmail.com	Cost Center Code : 90192026 Cost Center Name : <u>Dominos</u> Project ID : PO Category : Capex NSO	Payment Term : Advance payment - 50% along with work order. Balance 50% after work completion & submission of invoice. PO Creation Date : 06/06/2024 PO Approval Date : 07/06/2024 PO Currency : INR Buyer Name : Binu Balachandran

Sr. No	Item Code	HSN / SAC	Item Name	Item Description	Pur. Grp.	Qty	UOM	Basic Rate	Dis%	Net Rate	Total Amount	SGST %	CGST %	Gross Total Amount
1		84241000	Fire Sprinkler System	Fire Sprinkler System	C01	1.00	NOS	120,000.00	0.00	120,000.00	120,000.00	9	9	141,600.00

Total Qty : 1.00

Total Basic PO Amount	120,000.00
Total Other Charges	
SGST Amount	10,800.00
CGST Amount	10,800.00
<b>Grand Total PO Amount</b>	<b>141,600.00</b>

Amount In Words : Rupees One Lakh Fourty One Thousand Six Hundred Only

Remarks :


Standard Terms And Condition :

Completion / Delivery TimeLine : 1 Months


Mobilization Date : 13/06/2024

Defects Liability Period :

Retention Percentage : 0



ItemCode :							
ItemName : Fire Sprinkler System							
Sr No	Item Code	Item Name	UOM	Remarks	Quantity	Supplier Rate	Amount
1	A	FIRE SPRINKLER SYSTEM			0.00	0.00	0.00
2	A.1	Supply, Installation, Testing Commissioning of Automatic Concealed Fire Sprinkler Heads (Quick Response) (Bulb type Sprinklers) with adjustable Escutcheon plates (Rosette plates). Standard Temperature Response with 5mm glass bulb, Temperature rating of 68° C, K-factor of 80, Nominal Thread size of 1 2 NPT (15mm) and an Orifice size of 13mm with a Max. Working Pressure of 12 Bar (Factory hydrostatic test pressure of 35 Bar) and to be Manufactured Certified to UL 199. Shall also include suspending arrangements with ceiling wall etc.			0.00	0.00	0.00
3		FIRE SPRINKLER PIPE VALVES ACCESSORIES			0.00	0.00	0.00
4	A.3	Supply, Installation, Testing Commissioning of Cast Iron Butterfly Valve slimseal PN16 (working pressure of 16 Bar), standard flow control lever operated with stainless steel shaft disc, seat material with Black Nitrile EPDM, flanges nuts and bolts etc.			0.00	0.00	0.00
5	A.2	Supply, Installation, Testing Commissioning of Automatic Fire Sprinkler Heads (Quick Response) (Bulb type Sprinklers) with Standard Temperature Response with 5mm glass bulb, Temperature rating of 68° C - 93° C, K-factor of 80, Nominal Thread size of 1 2 NPT (15mm) and a Orifice size of 13mm with a Max. Working Pressure of 12 Bar (Factory hydrostatic test pressure of 35 Bar) and to be Manufactured Certified to UL 199. It shall also include suspending arrangements with ceiling wall etc.			0.00	0.00	0.00
6	A.7	Providing fixing testing and commissioning of UL Rated Braded SS Flexible pipe ( Assumed required at site) 1500 MM LONG	No.		12.00	2,500.00	30,000.00
7	A.6.2	40 mm Dia	Mtr		15.00	1,000.00	15,000.00
8	A.3.1	65 mm Dia	Nos		1.00	5,500.00	5,500.00
9		FIRE SPRINKLER PIPING			0.00	0.00	0.00
10	A.4	Supply, Installation, Testing Commissioning of Brass body Test And Drain Valve with Sight Glass, working pressure of 20 Bar (300 PSI), standard lever operated with stainless steel stem lever, with necessary weldable fittings in position as per drawings site conditions.			0.00	0.00	0.00
11	A.5	Supply, Installation, Testing Commissioning of Flow Switch on Sprinkler distribution header pipe with a working pressure of 31 Bar (450 PSI) and a flow sensitivity range of 4-10 GPM (15 - 38 LPM) on each floor zone inside proposed demise area tap of point, shall be connected to fire alarm panel through cable.			0.00	0.00	0.00
12	A.5.1	65 mm Dia	Nos		1.00	5,500.00	5,500.00



13	A.6	Supply, Installation, Testing Commissioning of GI C Class Fire Sprinkler Pipe confirming to IS 1239 with all fittings like bends, tees, flanges, nut, bolt and washers etc, and proper pipe supports to not more than 3 meter apart of the pipe length. The pipe work shall be hydrostatically tested for not less than 2 hours at 15 Bar (or 1.5 times the working) pressure without leak. The pipes are to be applied with 2 coats of primer (indicated film thickness, dry 50 microns) and 2 coats of enamel finish paint of approved colour (indicated film thickness, dry 30 microns)			0.00	0.00	0.00
14	A.6.4	65 mm Dia	Mtr		2.00	1,350.00	2,700.00
15	A.6.3	50 mm Dia	Mtr		10.00	1,200.00	12,000.00
16		SPRINKLERS BRAIDED FLEXIBLE PIPE			0.00	0.00	0.00
17		AUTOMATIC FIRE SPRINKLER HEADS ACCESSORIES			0.00	0.00	0.00
18	A.1.1	Concealed Pendant type of 68° C (Chrome Finish Plate Cover)	Nos		9.00	2,250.00	20,250.00
19	A.1.2	Concealed Pendant type of 79° C (Chrome Finish Plate Cover)	Nos		3.00	2,450.00	7,350.00
20	A.4.1	25 mm Dia	Nos		1.00	700.00	700.00
20	A.6.1	25 mm Dia	Mtr		30.00	700.00	21,000.00
<b>Total :</b>					<b>84.00</b>		<b>120,000.00</b>

9



Order No.	Invoice Date	Invoice No.	Client Name	Project	Delivery Add	Billing Address			
<b>Performa Invoice</b>									
			Travel Food Services Pvt. Ltd	FIRE Sprinkler WORK	Flre Work Delhi T-1, Dominos	NEW Terminal - 1, Indra Gandhi International Airport, Domestic Departure SHA, Mehram Nagar, New Delhi, New Delhi, Delhi - 110037.			
						Client Detail			
						07AHQPA6815Q2ZQ			
						AHQPA6815Q			
						07AADCB2762L2ZJ			
						GST No. C.I.N.			
						HSN Code UOM QTY UNIT COST REMARKS			
<b>FIRE SPRINKLER SYSTEM</b>									
<b>AUTOMATIC FIRE SPRINKLER HEADS &amp; ACCESSORIES</b>									
A.1	Supply, Installation, Testing & Commissioning of Automatic Concealed Fire Sprinkler Heads (Quick Response) (Bulb type Sprinklers) with adjustable Escutcheon plates (Rosette plates), Standard Temperature Response with 5mm glass bulb, Temperature rating of 68° C, K-factor of 80, Nominal Thread size of 1/2" NPT (15mm) and an Orifice size of 13mm with a Max. Working Pressure of 12 Bar (Factory hydrostatic test pressure of 35 Bar) and to be Manufactured & Certified to UL 199, Shall also				Nos	8	2250	18000	
A.1.1	Concealed Pendant type of 68° C (Chrome Finish Plate Cover)				Nos	2	2450	4900	
A.1.2	Concealed Pendant type of 79° C (Chrome Finish Plate Cover)								
A.2	Supply, Installation, Testing & Commissioning of Automatic Fire Sprinkler Heads (Quick Response) (Bulb type Sprinklers) with Standard Temperature Response with 5mm glass bulb, Temperature rating of 68° C / 93° C, K-factor of 80, Nominal Thread size of 1/2" NPT (15mm) and a Orifice size of 13mm with a Max. Working Pressure of 12 Bar (Factory hydrostatic test pressure of 35 Bar) and to be Manufactured & Certified to UL 199. It shall also include suspending arrangements with ceiling/wall etc.								
A.2.1	Upright type of 68° C (Finishing - Chrome Plated)								
<b>FIRE SPRINKLER PIPE VALVES &amp; ACCESSORIES</b>									
A.3	Supply, Installation, Testing & Commissioning of Cast Iron Butterfly Valve slimseal PN16 (working pressure of 16 Bar), standard flow control lever operated with stainless steel shaft & disc, seat material with Black Nitrile / EPDM, flanges nuts and bolts etc.				Nos	0	1450	0	
A.3.1	65 mm Dia								
A.4	Supply, Installation, Testing & Commissioning of Brass body Test And Drain Valve with Sight Glass, working pressure of 20 Bar (300 PSI), standard lever operated with stainless steel stem & lever, with necessary weldable fittings in position as per drawings / site conditions.				Nos	1	5500	5500	
A.4.1	25 mm Dia								
A.5	Supply, Installation, Testing & Commissioning of Flow Switch on Sprinkler distribution header pipe with a working pressure of 31 Bar (450 PSI) and a flow sensitivity range of 4-10 GPM (15 - 38 LPM) on each floor cable, / zone / inside proposed demise area tap of point, shall be connected to fire alarm panel through				Nos	1	700	700	
A.5.1	65 mm Dia								
<b>FIRE SPRINKLER PIPING</b>									
A.6	Supply, Installation, Testing & Commissioning of GI "C" Class Fire Sprinkler Pipe conforming to IS: 1239 with all fittings like bends, tees, flanges, nut, bolt and washers etc, and proper pipe supports to not more than 3 meter apart of the pipe length. The pipe work shall be hydrostatically tested for not less than 2 hours at 15 Bar (or 1.5 times the working) pressure without leak. The pipes are to be applied with 2 coats of primer (indicated film thickness, dry 50 microns) and 2 coats of enamel finish paint of approved colour (indicated film thickness, dry 30 microns)				Nos	0	5500	0	
A.6.1	25 mm Dia				Mtr	37	700	25900	
A.6.2	40 mm Dia				Mtr	18	1000	18000	
A.6.3	50 mm Dia				Mtr	12	1200	14400	
A.6.4	65 mm Dia				Mtr	5	1350	6750	
<b>SPRINKLERS BRAIDED FLEXIBLE PIPE</b>									
A.7	Providing & fixing testing and commissioning of UL Rated Braided SS Flexible pipe ( Assumed required at site) 1500 MM LONG				No.	10	2500	25000	
<b>TOTAL</b>									
CGST@9%									
SGST@9%									
<b>GRAND TOTAL</b>									

For Pioneer Project Solution

Auth Signatory