

PIONEER PROJECT SOLUTION

HVAC Design & Built Contractors

Registered Office : 12A/20B, Gali No. 10, Vijay Mohallah, Maujpur, Delhi-110053

Tel.: 9810634901 Website : www.pioneerprojects.in Email : projectspioneer@gmail.com


Branch : E-93-B, First Floor, Shaheen Bagh, Abul Fazal Enclave-II, Jamia Nagar, Okhla, New Delhi-110025

TAX INVOICE

Order No.	TFSPL/PO/23-24/000377	GST No.	07AHQPA6815Q2ZQ			
Invoice Date	15/05/2024	Pan No.	AHQPA6815Q			
Invoice No.	281-2024-25	Client Detail				
Client Name	Travel Food Services Pvt. Ltd					
		GST No.	07AADCB2762L2ZJ			
		C.I.N.				
Project	HVAC HIGH SIDE	Billing Address		NEW Terminal - 1, Indra Gandhi Internation Airport, Domestic Departure SHA, Mehram Nagar, New Delhi, New Delhi, Delhi - 110037.		
Delivery Add	DEL T1 TACOBELL					
Sr. No.	Description	HSN Code	Unit	Qty	Rate	Amount
1	Ceiling Suspended Air Handling Units 5000 CFM, 9.5 TR Supply & Installation of double skin ceiling suspended air handling units complete with 25mm thick insulated panels, forward curved DIDW Blower, cooling coil section with 6 RowDX-CHW coil (coil Thickness -0.5mm), filter section with filters (EU-4), fan motor, drive set with double belt, mounting base damper etc.as per specifications and drawings. AHU shall have DOL Starter panel within 7.0 KW and above 7.0 KW star delte starter to be used. Motor should be IP 55 TEFC. (Fan Make: Kruger/Nicotra). Coil temperature should be 12 deg C. AHU should be complete with filter frame & with filter. Static Pressure: 35mm AHUs shall be provided with Thermal Break Profile. a) Fan Outlet Velocity should not exceed 1000 FPM b) Coil face velocity should no exceed 500 FPM c) Filter velocity should not exceed 500 FPM	84151090	Nos	1	165,000	165,000
Total						165,000
CGST@14%						23,100
SGST@14%						23,100
Grand Total						211,200

For Pioneer Project Solution

Mohd Ashraf
9810634901



Mohd Ashraf
17/05/24

PIONEER PROJECT SOLUTION

HVAC Design & Built Contractors

Registered Office : 12A/20B, Gali No. 10, Vijay Mohallah, Maujpur, Delhi-110053

Tel.: 9810634901 Website : www.pioneerprojects.in Email : projectspioneer@gmail.com

Branch : E-93-B, First Floor, Shaheen Bagh, Abul Fazal Enclave-II, Jamia Nagar, Okhla, New Delhi-110025


GST No.: 07AHQPA6815Q2ZQ

TAX INVOICE

Order No.	TF SPL/PO/23-24/000119	GST No.	07AHQPA6815Q2ZQ					
Invoice Date	15/05/2024	Pan No.	AHQPA6815Q					
Invoice No.	280-2024-25	Client Detail						
Client Name	Travel Food Services Pvt. Ltd							
Project		GST No.	07AADCB2762LZZI					
Delivery Add		C.I.N.	NEW Terminal - 1, Indra Gandhi Internation Airport, Domestic Departure SHA, Mehram Nagar, New Delhi, New Delhi, Delhi - 110037.					
Sr. No.		Description		HSN Code	Unit	Qty	Rate	Amount
1.1	Fresh Air Unit - 2500 CFM Supply & Installation of the following cabinet type Fresh Air Fans with Forward curved inclined type heavy duty DIDW centrifugal fan with 3 phase TEFC with IP55 protection & class F insulation, Double skin construction complete with Filters, adjusting brackets, twin 'V' drive belt , vibration spring isolators, canvas connection and epoxy painted all as per specs. (Fan Make: Kruger/Nicotra. Motor : Crompton/Havells/BB)Static Pressure: 65 mm		84145930	Nos	1	115000	115000	
1.2	Dry Scrubber - 3500 CFM Supply & installation of DRY scrubber each comprising of extract air intake section, electrostatic precipitation technology, dry type air cleaner to remove oil, smoke and fumes from exhaust air. Electrostatic section shall be made of 16 gauge galvanized sheet, high bake epoxy powder coated, washable type even air flow distribution plate, stainless steel spiked ionizers to create high voltage DC field, honey comb patented cylindrical structure filter cell which should be alternatively charged positive and negative with large collecting area , to work as magnet for charged smoke and oil particles. Average efficiency of 90-95% in single pass as per ASHRAE test method. Electrostatic Precipitator should be able to charge particles from 0.01 micron to 10 microns through solid state power supply. Collector cell should be of permanent type and incorporate slide out facility for easy removal for cleaning. Power supplies shall be 100% solid state UL Listed, Module of capacity below shall be equipped with multiple protection functions for power and overload and overheating with interlock switch for safety as per approved specification and drawings) (Air Moving Capacities are - 8000 cfm 90 mmwg S.P.)Make -Rydair, Trion		84798999	Nos	1	165000	165000	
1.4	Exhaust Air Unit - 3500 CFM Supply & Installation of Floor Mounted type Cabinete type Exhaust Centrifugal backward inclined DIDW blower with suitable high static pressure to create the required intake velocities and over come the pressure loss at the inlet of filters and ducts. DIDW Centrifugal blower. (Motor outside the effluent air stream.) backward inclined, non over loading type. (smaller motor) mounted directly on motor shaft & twin belt drive system. (slip losses and lesser maintenance) Dynamically balanced to provide a vibration free operation.Fan to be direct driven to motor. Multiblade box type zero leakage manually operated extruded aluminium volume control dampers shall be factory fitted at outlet of Exhaust Fan.Static Pressure: 80 mm , Make -Kruger/Greenheck/System Air/Wolter/ Caryaire/ Nicotra		84145990	Nos	1	125000	125000	
Total							405,000	
CGST@9%							56,700	
SGST@9%							56,700	
Grand Total							518,400	

For Pioneer Project Solution

Mohd Ashraf
9810634901



Mohd Ashraf
17/05/24