



# SAI REFRIGERATION ENGINEERING

All Refrigeration Equipments Sales & Service

To,  
**Semolina Kitchens Pvt Ltd**  
Thiruvananthapuram International Airport T2  
Airport Road, Chackai  
Thiruvananthapuram  
Kerala - 695024  
GST: 32ABICS8699F1ZS

Date: 26.04.24  
Invoice No: 141

## TAX INVOICE

Sl. No	Name of the product	Rate	Qty	Amount
1	Blue star Under Ground Chiller New Compressor Cost Model No (EMBRACO FFU130HAX) S No. 513200765F23PL7JO	12850	1	12850
2	Blue star Under Ground Chiller - Pressure Testing Welding, Vacuum & Gas Charging all material and Service charge	7500	1	7500
3	Blue star Under Ground Chiller Door Gas cut -- Per Mt Rs.850/-	850	8	6800
4	Blue Star Under Ground Chiller Door gas cut magnate Per Mt Rs. 620/-	620	8	4960
5	Blue Star Under Ground Chiller Door gas cut magnate fitting and service charge ( 3 Door)	1000	3	3000
	<b>TOTAL</b>			35110
	IGST 18%			6320
	<b>GRAND TOTAL</b>			<b>41430</b>

in words : **Forty - one Thousand and Four Hundred Thirty Only**

BANK ACCOUNT NO : 1822050000134  
IFSC Code : PUNB0182220  
Bank : PUNJAB NATIONAL BANK  
Branch : Perambur Branch, Chennai

For SAI REFRIGERATION ENGINEERING

Authorized Signatory

*Work completed  
under observation  
Bis*



Mobile : 98407 11597

Service Call Report No. 1427

# SAI REFRIGERATION ENGINEERING

Date : 26/4/2024

No.40 (Old 107-B), Kennady Square Main Road,  
Sembiam, Chennai - 600 011. E-mail : sairefriengg@yahoo.com

SRE No.

Customer Name & Address

Semoline kitchen Pvt Ltd  
Thiruvananthapuram Airport T2  
Ampore Ponnachackai  
Kerala - 695024

Location : Lounge

Equipment : Underground Chiller (BLUE STAR)

Model No.: UC3100A

Serial No.: 2BB1A0R1B176001b

Installation     Breakdown Call     AMC Call     Warrant Call

Voltage : 220

Phase : 1

KW / AMPS : 1.2

Nature of Complaint : Not working

Work Done

attend The Check The Under ground Chiller  
Chang The new Compressor Pressure Tester, welding,  
Vacuum and gas Charge until working properly (to c)

Material Requirement     Replacement Material

S.No.	Description	Rate	Quantity	Billable	Remarks
1	Compressor		1		
2	Pressure		1		
3	Charging valve		1		
4	Copper pipe		1		
5	R-134a gas		1kg		

Comments of Customer.....

Comments of Service Engineer

Machine is performing Satisfactory

Name : B. Venkat Subramaniam

Name : M. Ananth Kumar

Signature & Stamp :

Signature :