



1) DO NOT SCALE THE DRAWINGS FOLLOW THE WRITTEN DIMENSIONS.
 2) ALL THE MATERIALS FOR CONSTRUCTION SHALL BE TO 'IS' STANDARDS AND AS PER THE SPECIFICATIONS BY THE ARCHITECT.
 3) ANY AMBIGUITY FOUND IN THE DRAWINGS SHALL BE IMMEDIATELY BROUGHT TO THE NOTICE OF AN ARCHITECT.

REVISIONS		
DESCRIPTION	DATE	
	YYYY-MM-DD	
	YYYY-MM-DD	
	YYYY-MM-DD	

SIGN/STAMP

AIRPORT NAME
 LUCKNOW AIRPORT TERMINAL 3

1 COORDINATED LAYOUT
 Scale:-1:75

FIRE FIGHTING LEGEND		
S.NO.	DESCRIPTION	SYMBOL
1.	SPRINKLER BRANCH PIPE LINE (100Ø)	
2.	SPRINKLER BRANCH PIPE LINE (80Ø)	
3.	SPRINKLER BRANCH PIPE LINE (65Ø)	
4.	SPRINKLER BRANCH PIPE LINE (50Ø)	
5.	SPRINKLER BRANCH PIPE LINE (40Ø)	
6.	SPRINKLER BRANCH PIPE LINE (32Ø)	
7.	SPRINKLER BRANCH PIPE LINE (25Ø)	
8.	BUTTERFLY VALVE	
9.	REDUCER	
10.	COVERAGE AREA	

PIPE SIZE SELECTION CHART		
PIPE DESCRIPTION	NO'S	
25 MM	1 to 2	
32 MM	3	
40 MM	4 to 6	
50 MM	7 to 18	
65 MM	19 to 50	
80 MM	51 to 100	

FIRE FIGHTING LEGEND		
DESCRIPTION	QTY.	
BELOW FALSE CEILING SPRINKLER -MRke :-tyco/viking temp rating:-68°(qr) standard coverage discharge coefficient k-6.6,quick response UL listed & EN approved	30	
ABOVE FALSE CEILING (UPRIGHT SPRINKLER) -MRke :-tyco/viking temp rating:-68°(qr) standard coverage discharge coefficient k-6.6,quick response UL listed & EN approved.	30	
BELOW FALSE CEILING SPRINKLER -MRke :-tyco/viking temp rating:-79°(qr) standard coverage discharge coefficient k-6.6,quick response UL listed & EN approved for high temperature area in kitchen,temp rating shall be 79°c(qr)	8	
ABOVE FALSE CEILING (UPRIGHT SPRINKLER) -MRke :-tyco/viking temp rating:-79°(qr) standard coverage discharge coefficient k-6.6,quick response UL listed & EN approved for high temperature area in kitchen,temp rating shall be 79°c(qr)	8	

CCTV SYSTEM LEGEND			
S.NO	DESCRIPTION	NOS	LEGEND
1	Ceiling mounted dome camera	16	
2	TFT 15" High resolution monitor with power supply.	01	
3	SITC of power supply & DVR	01	

LEGEND		
SYMBOL	DESCRIPTION	QTY
	BFC SMOKE DETECTOR	13
	AFC SMOKE DETECTOR WITH RESPONSE INDICATOR	13
	HOOTER	03
	MRNUAL CALL POINT	03
	FIRE JUNCTION BOX	01
	FIRE EXIT	16
	FAS LOOPING	
	HEAT DETECTOR	1

FIRE EXTINGUISHER			
S.NO.	SYMBOL	DESCRIPTION	NOS
1.		4.0Kgs Dry powder Type ABC type (on S.s Stand)	05
2.		4.5 KG co2 portable fire extinguisher (on S.s Stand)	01
3.		6.0Kgs K Type (on S.s Stand)	02
4.		FIRE BLANKET - 6' X 4'	03

LIGHT LEGEND			
S.NO	SYMBOL	SPECIFICATION	QTY.
1.		Ceiling suspended linear lights as approved (1000 mm Long)	07
2.		T5 Tube lights in kitchen area as approved (1200 mm Long)	04
3.		Emergency Linear Lights	01
4.		Emergency tube light in BOH	01
5.		Ceiling suspended decorative light	09
6.		T5 Tube lights in kitchen area as approved (1200 mm Long)	03
7.		Ceiling suspended linear lights as approved (1200 mm Long)	36

LOCATION
 DOMESTIC SHA
 BRAND NAME / PROJECT NAME
 BUDWEISER
 DRAWING TYPE
 GFC

COORDINATED LAYOUT

DRN BY	MR	SCALE	1:75	R0
CHKD BY	AP	REV		
DATE	2024-02-07			

DWG NO. TFS_LK0_DSHA_BD_GFC-B-100
 ARCHITECT: Genesis Architects Pvt. Ltd.
 SHIV SAGAR ESTATE
 ANNIE BESANT ROAD,
 WORLI, MUMBAI 400018.
 PH: +91 (22) 4322 4322