

# BATTERY HEALTH CHECKUP REPORT

**KAPCO BANQUETS AND CATERING SERVICES PVT LTD**

**By : Trident services Pvt Ltd. Mumbai**

Representative :- Mr. Deepak Chaudhary

Health check date :- 17/10/2024

Location :- Worli

Contact Person :- Mr. Harish

Contact No :- 9967898898

Mail Id :- maintenance@kapcocatering.com



**Sales and  
Service  
India**

**Sales  
Service  
Support**

# Tools Safety Equipment used :

1. Cummins Battery Health Check Meter
2. Hand Gloves
3. Safety Goggles
4. Safety Shoes



# Health Check Summary :



## Condition of battery Ageing of battery

Summary based on health check up

Description	Qty
No of batteries checked	02
No of batteries found good	00
No of batteries found weak	02

Summary based on Ageing

Description	Qty
Batteries less than one year	00
Batteries less than two year	00
Batteries more than two year	02

We are recommending to replace 02 Battery on top priority as the battery found weak as per battery health meter report. The health meter report is attached in subsequent slides.

# Battery Reports :



# Recommendation :

Sr. No.	ESN	Battery Part no.	Battery make	Last Replacement Date	Battery Voltage	CCA measured by Meter	Reference (input ) CCA	Remark
1	84515225	AX1012843	CUMMINS	2022	13.29	523CCA	650CCA	REPLACE BATTERY
2	84515225	AX1012843	CUMMINS	2022	13.26	521CCA	650CCA	REPLACE BATTERY



- Battery voltage showing low CCA against required CCA. Need to be replace

## **Conclusion:**

We have checked total **02** battery **02** battery need **to be replaced** because of low CCA.

**Battery replacement is recommended to avoid :**

- ✓ **DG STARTING FAILURE**
- ✓ **STARTER FAILURE**
- ✓ **CHARGING SYSTEM FAILURE**
- ✓ **CONTROLLER FAILURE**