



Fire Alarm Legend		
S.NO.	SYMBOL	ITEM DESCRIPTION
1		Smoke Detector
2		Heat Detector
3		Hooter
4		Response Indicator
5		MCP (Manual Call Point)
6		2C x 1.5 Sq.mm FRLS Fire Alarm Cable

NOTES:

1. SYMBOLS ARE NOT TO SCALE.
2. MANUAL CALL POINTS TO BE PROVIDED AT 1.2M ABOVE F.F.L IN CONCEALED M.S BOX OF SUITABLE SIZE.
3. HOOTERS TO BE PROVIDED IN CONCEALED M.S BOX OF SUITABLE SIZE.
4. THE CABLES CONNECTED TO SMOKE DETECTORS, HEAT DETECTORS, MANUAL CALL POINTS, HOOTERS WILL BE 2 CORE 1.5 SQ.MM. FRLS CABLE UNLESS OTHERWISE STATED.
5. AFTER EVERY 20 DETECTORS CONTRACTOR SHOULD BE CONSIDERED A FAULT ISOLATOR.
6. FIRE ALARM PANEL SHOULD BE INTEGRATED WITH PA SYSTEM SO AS TO HAVE AUTOMATIC FIRE EVACUATION MESSAGE INCASE OF FIRE EMERGENCY.

REV NO.	DATE	DESCRIPTION	DESIGNED	DRAWN	CHECKED	APPROVED
REVISIONS						
CHECKED BY	SIGN	DATE	CHECKED BY	SIGN	DATE	
ARCHITECTURE			HVAC			
CIVIL & STRUCTURAL			FPS			
ELECTRICAL			PIPING			
ELV SYSTEM			PHE			

tfs FOR :- **TRAVEL FOOD SERVICES PVT LTD**
 Travel Food Services VAIBHAV DOSHI (HEAD - DESIGN)
 vaibhav.doshi@travelfoodservices.com

PLUGD
 ARCHITECT
 AR. RITIKA MALIK & AR. SOURABH KHURANA

MEP CONSULTANTS:
 PILLARPLUS PVT LTD-The New Age MEP Consultancy Firm
 Plot No. 45,46 guru Jambheshwar Nagar A,
 Vijay Dwar, Gandhipath, Jaipur-302021
 JAIPUR | GURGAON | BANGLORE
 Email: contact@pillarplus.com | Contact No: +91-9799858301 | Website: www.pillarplus.com

SCALE	DATE	PREPARED BY	CHEKED BY	APPROVED BY
NTS	10-01-2024	RAJESH PRAJAPAT	RAJESH PRAJAPAT	RUSHIL MATHUR

PROJECT
UNA FOOD COURT

Job No:	BUILDING NAME	COMMON AREA
	DRAWING TITLE	Fire Alarm Layout
	DRAWING NUMBER:	

SCALE: 1:100	SHEET SIZE: A1	11-01-2024	REV. NO: R0
RELEASED FOR	<input type="checkbox"/> INFORMATION	<input checked="" type="checkbox"/> APPROVAL	<input type="checkbox"/> CONSTRUCTION