

## Trupti Dalvi

---

**From:** Santosh Tambe  
**Sent:** 09 January 2024 12:59  
**To:** Trupti Dalvi; Ajit Yadav  
**Cc:** Shama Nair; Puneeth Kumar; Venkat Subramanian; Akshay Sharma; Ameet Koomar; Suraj Kumbhar; Nimisha Jadhav; Lovejot Sekhon; Kamal Saraf; Herambraj Sonawane; Swapnil Sutar; Sandeep Bhat; Abdul Rehman; Prakash Mistry; Khushbu Verma; Sarvesh Patil; 'Sonali Dhadve'; Saeed Khan; Ansari Faheem Noor Hasan  
**Subject:** FW: Request for Ducting Layout: Malabar Outlet Kitchen - TRV - T2  
**Attachments:** MEP Design Proposal\_24\_06\_Malabar Kitchen\_Trivendrum.pdf

Dear Trupti ,

Kindly upload the PR request on safal for TRV .Please take it on top priority .

Regards  
Santosh TAMBE

---

**From:** Nimish Shah <[nimish.shah@meptekconsultants.com](mailto:nimish.shah@meptekconsultants.com)>  
**Sent:** 9 January 2024 12:28 PM  
**To:** Ajit Yadav <[ajit.yadav@travelfoodservices.com](mailto:ajit.yadav@travelfoodservices.com)>; [safdar@meptekconsultants.com](mailto:safdar@meptekconsultants.com)  
**Cc:** Shama Nair <[shama.nair@travelfoodservices.com](mailto:shama.nair@travelfoodservices.com)>; Nimisha Jadhav <[nimisha.jadhav@travelfoodservices.com](mailto:nimisha.jadhav@travelfoodservices.com)>; Shashank Mahadik <[shashank.mahadik@travelfoodservices.com](mailto:shashank.mahadik@travelfoodservices.com)>; Saeed Khan <[saeed.khan@travelfoodservices.com](mailto:saeed.khan@travelfoodservices.com)>; Venkat Subramanian <[trivandrum.maintenance@travelfoodservices.com](mailto:trivandrum.maintenance@travelfoodservices.com)>; Puneeth Kumar <[puneeth.kumar@travelfoodservices.com](mailto:puneeth.kumar@travelfoodservices.com)>; Sindhu Thomas <[sindhu.thomas@travelfoodservices.com](mailto:sindhu.thomas@travelfoodservices.com)>; 'Lovejot Sekhon' <[lovejot.sekhon@k-corp.in](mailto:lovejot.sekhon@k-corp.in)>; 'Binu Balachandran' <[binu.balachandran@k-corp.in](mailto:binu.balachandran@k-corp.in)>; 'Stephen P' <[stephen.p@k-corp.in](mailto:stephen.p@k-corp.in)>; Akshay Sharma <[akshay.sharma@semolinakitchens.com](mailto:akshay.sharma@semolinakitchens.com)>; Prakash Mistry <[prakash.mistry@travelfoodservices.com](mailto:prakash.mistry@travelfoodservices.com)>; Khushbu Verma <[khushbu.dayal@travelfoodservices.com](mailto:khushbu.dayal@travelfoodservices.com)>; Santosh Tambe <[santosh.tambe@travelfoodservices.com](mailto:santosh.tambe@travelfoodservices.com)>; 'Ameet Koomar' <[Ameet.Koomar@adani.com](mailto:Ameet.Koomar@adani.com)>  
**Subject:** RE: Request for Ducting Layout: Malabar Outlet Kitchen - TRV - T2

You don't often get email from [nimish.shah@meptekconsultants.com](mailto:nimish.shah@meptekconsultants.com). [Learn why this is important](#)

**CAUTION:** This email originated from outside of the organization. Do not click links or open attachments unless you recognize the sender and know the content is safe.

Dear Ajit,

PFA – Design Fee proposal for all 3 outlets at TRV Airport.

Detailed scope as discussed is mentioned.

Pl confirm and issue Work order for us to proceed.

With Best regards,

**Nimish Shah**

Cell # 9833410610



209, Sumer Kendra, Behind Mahindra Towers,  
Pandurang Budhkar Marg, Worli,  
Mumbai - 400018

---

**From:** Ajit Yadav [<mailto:ajit.yadav@travelfoodservices.com>]

**Sent:** Monday, January 8, 2024 1:38 PM

**To:** [safdar@mepstekconsultants.com](mailto:safdar@mepstekconsultants.com)

**Cc:** Shama Nair <[shama.nair@travelfoodservices.com](mailto:shama.nair@travelfoodservices.com)>; Nimisha Jadhav <[nimisha.jadhav@travelfoodservices.com](mailto:nimisha.jadhav@travelfoodservices.com)>; Shashank Mahadik <[shashank.mahadik@travelfoodservices.com](mailto:shashank.mahadik@travelfoodservices.com)>; Saeed Khan <[saeed.khan@travelfoodservices.com](mailto:saeed.khan@travelfoodservices.com)>; Venkat Subramanian <[trivandrum.maintenance@travelfoodservices.com](mailto:trivandrum.maintenance@travelfoodservices.com)>; Puneeth Kumar <[puneeth.kumar@travelfoodservices.com](mailto:puneeth.kumar@travelfoodservices.com)>; Sindhu Thomas <[sindhu.thomas@travelfoodservices.com](mailto:sindhu.thomas@travelfoodservices.com)>; 'Lovejot Sekhon' <[lovejot.sekhon@k-corp.in](mailto:lovejot.sekhon@k-corp.in)>; 'Binu Balachandran' <[binu.balachandran@k-corp.in](mailto:binu.balachandran@k-corp.in)>; 'Stephen P' <[stephen.p@k-corp.in](mailto:stephen.p@k-corp.in)>; Akshay Sharma <[akshay.sharma@semolinakitchens.com](mailto:akshay.sharma@semolinakitchens.com)>; Prakash Mistry <[prakash.mistry@travelfoodservices.com](mailto:prakash.mistry@travelfoodservices.com)>; Khushbu Verma <[khushbu.dayal@travelfoodservices.com](mailto:khushbu.dayal@travelfoodservices.com)>; Santosh Tambe <[santosh.tambe@travelfoodservices.com](mailto:santosh.tambe@travelfoodservices.com)>; 'Ameet Koomar' <[Ameet.Koomar@adani.com](mailto:Ameet.Koomar@adani.com)>; Nimish Shah <[nimish.shah@mepstekconsultants.com](mailto:nimish.shah@mepstekconsultants.com)>

**Subject:** RE: Request for Ducting Layout: Malabar Outlet Kitchen - TRV - T2

Hello Safdar,

Could you kindly offer me an update on the quotation for the 3 Outlets DWG docket which I assume you have reviewed thoroughly?

Regards,  
Ajit R Yadav  
8898931514  
Travel Food Services Pvt. Ltd.  
Shiv Sagar Estate, A-Block, 1st Floor, Dr. Annie Besant Road,  
Worli, Mumbai-400018.



---

**From:** Ajit Yadav  
**Sent:** 5 January 2024 05:18 PM  
**To:** [safdar@mepstekconsultants.com](mailto:safdar@mepstekconsultants.com)  
**Cc:** Shama Nair <[shama.nair@travelfoodservices.com](mailto:shama.nair@travelfoodservices.com)>; Nimisha Jadhav <[nimisha.jadhav@travelfoodservices.com](mailto:nimisha.jadhav@travelfoodservices.com)>; Shashank Mahadik <[shashank.mahadik@travelfoodservices.com](mailto:shashank.mahadik@travelfoodservices.com)>; Saeed Khan <[saeed.khan@travelfoodservices.com](mailto:saeed.khan@travelfoodservices.com)>; Venkat Subramanian <[trivandrum.maintenance@travelfoodservices.com](mailto:trivandrum.maintenance@travelfoodservices.com)>; Puneeth Kumar <[puneeth.kumar@travelfoodservices.com](mailto:puneeth.kumar@travelfoodservices.com)>; Sindhu Thomas <[sindhu.thomas@travelfoodservices.com](mailto:sindhu.thomas@travelfoodservices.com)>; 'Lovejot Sekhon' <[lovejot.sekhon@k-corp.in](mailto:lovejot.sekhon@k-corp.in)>; 'Binu Balachandran' <[binu.balachandran@k-corp.in](mailto:binu.balachandran@k-corp.in)>; 'Stephen P' <[stephen.p@k-corp.in](mailto:stephen.p@k-corp.in)>; Akshay Sharma <[akshay.sharma@semolinakitchens.com](mailto:akshay.sharma@semolinakitchens.com)>; Prakash Mistry <[prakash.mistry@travelfoodservices.com](mailto:prakash.mistry@travelfoodservices.com)>; Khushbu Verma <[khushbu.dayal@travelfoodservices.com](mailto:khushbu.dayal@travelfoodservices.com)>; Santosh Tambe <[santosh.tambe@travelfoodservices.com](mailto:santosh.tambe@travelfoodservices.com)>; 'Ameet Koomar' <[Ameet.Koomar@adani.com](mailto:Ameet.Koomar@adani.com)>; Nimish Shah <[nimish.shah@mepstekconsultants.com](mailto:nimish.shah@mepstekconsultants.com)>  
**Subject:** RE: Request for Ducting Layout: Malabar Outlet Kitchen - TRV - T2

Hello Safdar,

I trust that you have thoroughly reviewed the entirety of the documentation pertaining to the three outlets. At this time, I would like to kindly request that you provide us with your quotation for the preliminary phase.

Regards,  
Ajit R Yadav  
8898931514  
Travel Food Services Pvt. Ltd.

Shiv Sagar Estate, A-Block, 1st Floor, Dr. Annie Besant Road,  
Worli, Mumbai-400018.



---

**From:** Ajit Yadav

**Sent:** 29 December 2023 12:39 PM

**To:** [safdar@mepstekconsultants.com](mailto:safdar@mepstekconsultants.com)

**Cc:** Shama Nair <[shama.nair@travelfoodservices.com](mailto:shama.nair@travelfoodservices.com)>; Nimisha Jadhav <[nimisha.jadhav@travelfoodservices.com](mailto:nimisha.jadhav@travelfoodservices.com)>; Shashank Mahadik <[shashank.mahadik@travelfoodservices.com](mailto:shashank.mahadik@travelfoodservices.com)>; Saeed Khan <[saeed.khan@travelfoodservices.com](mailto:saeed.khan@travelfoodservices.com)>; Venkat Subramanian <[trivandrum.maintenance@travelfoodservices.com](mailto:trivandrum.maintenance@travelfoodservices.com)>; Puneeth Kumar <[puneeth.kumar@travelfoodservices.com](mailto:puneeth.kumar@travelfoodservices.com)>; Sindhu Thomas <[sindhu.thomas@travelfoodservices.com](mailto:sindhu.thomas@travelfoodservices.com)>; 'Lovejot Sekhon' <[lovejot.sekhon@k-corp.in](mailto:lovejot.sekhon@k-corp.in)>; 'Binu Balachandran' <[binu.balachandran@k-corp.in](mailto:binu.balachandran@k-corp.in)>; 'Stephen P' <[stephen.p@k-corp.in](mailto:stephen.p@k-corp.in)>; Akshay Sharma <[akshay.sharma@semolinakitchens.com](mailto:akshay.sharma@semolinakitchens.com)>; Prakash Mistry <[prakash.mistry@travelfoodservices.com](mailto:prakash.mistry@travelfoodservices.com)>; Khushbu Verma <[khushbu.dayal@travelfoodservices.com](mailto:khushbu.dayal@travelfoodservices.com)>; Santosh Tambe <[santosh.tambe@travelfoodservices.com](mailto:santosh.tambe@travelfoodservices.com)>; 'Ameet Koomar' <[Ameet.Koomar@adani.com](mailto:Ameet.Koomar@adani.com)>; Nimish Shah <[nimish.shah@mepstekconsultants.com](mailto:nimish.shah@mepstekconsultants.com)>

**Subject:** RE: Request for Ducting Layout: Malabar Outlet Kitchen - TRV - T2

Hello Safdar,

PFA Docket for 3 Outlets.

Regards,

Ajit R Yadav

8898931514

Travel Food Services Pvt. Ltd.

Shiv Sagar Estate, A-Block, 1st Floor, Dr. Annie Besant Road,  
Worli, Mumbai-400018.



Creating memories and inspiring happiness through food, since 1972



**From:** Ajit Yadav

**Sent:** 29 December 2023 11:57 AM

**To:** [safdar@mepstekconsultants.com](mailto:safdar@mepstekconsultants.com)

**Cc:** Shama Nair <[shama.nair@travelfoodservices.com](mailto:shama.nair@travelfoodservices.com)>; Nimisha Jadhav <[nimisha.jadhav@travelfoodservices.com](mailto:nimisha.jadhav@travelfoodservices.com)>; Shashank Mahadik <[shashank.mahadik@travelfoodservices.com](mailto:shashank.mahadik@travelfoodservices.com)>; Saeed Khan <[saeed.khan@travelfoodservices.com](mailto:saeed.khan@travelfoodservices.com)>; Venkat Subramanian <[trivandrum.maintenance@travelfoodservices.com](mailto:trivandrum.maintenance@travelfoodservices.com)>; Puneeth Kumar <[puneeth.kumar@travelfoodservices.com](mailto:puneeth.kumar@travelfoodservices.com)>; Sindhu Thomas <[sindhu.thomas@travelfoodservices.com](mailto:sindhu.thomas@travelfoodservices.com)>; 'Lovejot Sekhon' <[lovejot.sekhon@k-corp.in](mailto:lovejot.sekhon@k-corp.in)>; 'Binu Balachandran' <[binu.balachandran@k-corp.in](mailto:binu.balachandran@k-corp.in)>; 'Stephen P' <[stephen.p@k-corp.in](mailto:stephen.p@k-corp.in)>; Akshay Sharma <[akshay.sharma@semolinakitchens.com](mailto:akshay.sharma@semolinakitchens.com)>; Prakash Mistry <[prakash.mistry@travelfoodservices.com](mailto:prakash.mistry@travelfoodservices.com)>; Khushbu Verma <[khushbu.dayal@travelfoodservices.com](mailto:khushbu.dayal@travelfoodservices.com)>; Santosh Tambe <[santosh.tambe@travelfoodservices.com](mailto:santosh.tambe@travelfoodservices.com)>; 'Ameet Koomar' <[Ameet.Koomar@adani.com](mailto:Ameet.Koomar@adani.com)>; Nimish Shah <[nimish.shah@mepstekconsultants.com](mailto:nimish.shah@mepstekconsultants.com)>

**Subject:** RE: Request for Ducting Layout: Malabar Outlet Kitchen - TRV - T2

Hello Safdar,

Your revert is highly awaited.

Regards,

Ajit R Yadav

8898931514

Travel Food Services Pvt. Ltd.

Shiv Sagar Estate, A-Block, 1st Floor, Dr. Annie Besant Road,

Worli, Mumbai-400018.



Creating memories and inspiring happiness through food, since 1972



**From:** Ajit Yadav

**Sent:** 20 December 2023 11:44 AM

**To:** [safdar@meptekconsultants.com](mailto:safdar@meptekconsultants.com)

**Cc:** Shama Nair <[shama.nair@travelfoodservices.com](mailto:shama.nair@travelfoodservices.com)>; Nimisha Jadhav <[nimisha.jadhav@travelfoodservices.com](mailto:nimisha.jadhav@travelfoodservices.com)>; Shashank Mahadik <[shashank.mahadik@travelfoodservices.com](mailto:shashank.mahadik@travelfoodservices.com)>; Saeed Khan <[saeed.khan@travelfoodservices.com](mailto:saeed.khan@travelfoodservices.com)>; Venkat Subramanian <[trivandrum.maintenance@travelfoodservices.com](mailto:trivandrum.maintenance@travelfoodservices.com)>; Puneeth Kumar <[puneeth.kumar@travelfoodservices.com](mailto:puneeth.kumar@travelfoodservices.com)>; Sindhu Thomas <[sindhu.thomas@travelfoodservices.com](mailto:sindhu.thomas@travelfoodservices.com)>; 'Lovejot Sekhon' <[lovejot.sekhon@k-corp.in](mailto:lovejot.sekhon@k-corp.in)>; 'Binu Balachandran' <[binu.balachandran@k-corp.in](mailto:binu.balachandran@k-corp.in)>; 'Stephen P' <[stephen.p@k-corp.in](mailto:stephen.p@k-corp.in)>; Akshay Sharma <[akshay.sharma@semolinakitchens.com](mailto:akshay.sharma@semolinakitchens.com)>; Prakash Mistry <[prakash.mistry@travelfoodservices.com](mailto:prakash.mistry@travelfoodservices.com)>; Khushbu Verma <[khushbu.dayal@travelfoodservices.com](mailto:khushbu.dayal@travelfoodservices.com)>; Santosh Tambe <[santosh.tambe@travelfoodservices.com](mailto:santosh.tambe@travelfoodservices.com)>; 'Ameet Koomar' <[Ameet.Koomar@adani.com](mailto:Ameet.Koomar@adani.com)>; Nimish Shah <[nimish.shah@meptekconsultants.com](mailto:nimish.shah@meptekconsultants.com)>

**Subject:** Request for Ducting Layout: Malabar Outlet Kitchen - TRV - T2

Hello Safdar,

Please find attached the kitchen layout for the Malabar Outlet (TRV – T2), designed by our in-house kitchen expert, Mr. Saeed Khan. The proposed location for the hood is clearly outlined in the document.

For additional reference, we have included site pictures. Should you need further clarification, feel free to reach out to Mr. Venkat (9884703317), our on-site maintenance personnel.

Kindly request your assistance in providing the ducting layout for both fresh air intake and exhaust systems.

SR.No.	Eq.No.	DESCRIPTION	MODEL NO	DIMENSIONS (Lx W x HT)	QTY	CFM
1	EH-01	SS.CROSS TYPE EXHAUST HOOD WITH FIRE SUPPRESSION SYSTEM	FABRICATED	2750 x 1150 x 600	1	3800
2	EH-02	SS.CROSS TYPE EXHAUST HOOD WITH FIRE SUPPRESSION SYSTEM	FABRICATED	3250 x 1150 x 600 (length wise in two Pcs)	1	4300

Regards,

Ajit R Yadav

8898931514

Travel Food Services Pvt. Ltd.

Shiv Sagar Estate, A-Block, 1st Floor, Dr. Annie Besant Road,

Worli, Mumbai-400018.



Creating memories and inspiring  
happiness through food, since 1972



**From:** Nimish Shah <[nimish.shah@meptekconsultants.com](mailto:nimish.shah@meptekconsultants.com)>

**Sent:** 19 December 2023 08:50 PM

**To:** Santosh Tambe <[santosh.tambe@travelfoodservices.com](mailto:santosh.tambe@travelfoodservices.com)>; Ajit Yadav <[ajit.yadav@travelfoodservices.com](mailto:ajit.yadav@travelfoodservices.com)>; [safdar@meptekconsultants.com](mailto:safdar@meptekconsultants.com)

**Cc:** Shama Nair <[shama.nair@travelfoodservices.com](mailto:shama.nair@travelfoodservices.com)>; Nimisha Jadhav <[nimisha.jadhav@travelfoodservices.com](mailto:nimisha.jadhav@travelfoodservices.com)>; Shashank Mahadik <[shashank.mahadik@travelfoodservices.com](mailto:shashank.mahadik@travelfoodservices.com)>; Saeed Khan <[saeed.khan@travelfoodservices.com](mailto:saeed.khan@travelfoodservices.com)>; Venkat Subramanian <[trivandrum.maintenance@travelfoodservices.com](mailto:trivandrum.maintenance@travelfoodservices.com)>; Puneeth Kumar <[puneeth.kumar@travelfoodservices.com](mailto:puneeth.kumar@travelfoodservices.com)>; Sindhu Thomas <[sindhu.thomas@travelfoodservices.com](mailto:sindhu.thomas@travelfoodservices.com)>; 'Lovejot Sekhon' <[lovejot.sekhon@k-corp.in](mailto:lovejot.sekhon@k-corp.in)>; 'Binu Balachandran' <[binu.balachandran@k-corp.in](mailto:binu.balachandran@k-corp.in)>; 'Stephen P' <[stephen.p@k-corp.in](mailto:stephen.p@k-corp.in)>; Akshay Sharma <[akshay.sharma@semolinakitchens.com](mailto:akshay.sharma@semolinakitchens.com)>; Prakash Mistry <[prakash.mistry@travelfoodservices.com](mailto:prakash.mistry@travelfoodservices.com)>; Khushbu Verma <[khushbu.dayal@travelfoodservices.com](mailto:khushbu.dayal@travelfoodservices.com)>; 'Ameet Koomar' <[Ameet.Koomar@adani.com](mailto:Ameet.Koomar@adani.com)>

**Subject:** RE: Request for Ducting Layout: Malabar Outlet Kitchen - TRV - T2

You don't often get email from [nimish.shah@meptekconsultants.com](mailto:nimish.shah@meptekconsultants.com). [Learn why this is important](#)

**CAUTION:** This email originated from outside of the organization. Do not click links or open attachments unless you recognize the sender and know the content is safe.

Dear Santosh,

+++ Looping Safdar Shaikh, from our HVAC Design Team Lead.

He will look into this project. His contact details – Cell no. 9221028008

He will connect with Ajit tomorrow for further details.

With Best regards,

**Nimish Shah**

Cell # 9833410610



209, Sumer Kendra, Behind Mahindra Towers,  
Pandurang Budhkar Marg, Worli,  
Mumbai - 400018

---

**From:** Santosh Tambe [<mailto:santosh.tambe@travelfoodservices.com>]

**Sent:** Monday, December 18, 2023 4:28 PM

**To:** Ajit Yadav <[ajit.yadav@travelfoodservices.com](mailto:ajit.yadav@travelfoodservices.com)>; [nimish.shah@mepstekconsultants.com](mailto:nimish.shah@mepstekconsultants.com)

**Cc:** Shama Nair <[shama.nair@travelfoodservices.com](mailto:shama.nair@travelfoodservices.com)>; Nimisha Jadhav <[nimisha.jadhav@travelfoodservices.com](mailto:nimisha.jadhav@travelfoodservices.com)>; Shashank Mahadik <[shashank.mahadik@travelfoodservices.com](mailto:shashank.mahadik@travelfoodservices.com)>; Saeed Khan <[saeed.khan@travelfoodservices.com](mailto:saeed.khan@travelfoodservices.com)>; Venkat Subramanian <[trivandrum.maintenance@travelfoodservices.com](mailto:trivandrum.maintenance@travelfoodservices.com)>; Puneeth Kumar <[puneeth.kumar@travelfoodservices.com](mailto:puneeth.kumar@travelfoodservices.com)>; Sindhu Thomas <[sindhu.thomas@travelfoodservices.com](mailto:sindhu.thomas@travelfoodservices.com)>; Lovejot Sekhon <[lovejot.sekhon@k-corp.in](mailto:lovejot.sekhon@k-corp.in)>; Binu Balachandran <[binu.balachandran@k-corp.in](mailto:binu.balachandran@k-corp.in)>; Stephen P <[stephen.p@k-corp.in](mailto:stephen.p@k-corp.in)>; Akshay Sharma <[akshay.sharma@semolinakitchens.com](mailto:akshay.sharma@semolinakitchens.com)>; Prakash Mistry <[prakash.mistry@travelfoodservices.com](mailto:prakash.mistry@travelfoodservices.com)>; Khushbu Verma <[khushbu.dayal@travelfoodservices.com](mailto:khushbu.dayal@travelfoodservices.com)>; Ameet Koomar <[Ameet.Koomar@adani.com](mailto:Ameet.Koomar@adani.com)>

**Subject:** RE: Request for Ducting Layout: Malabar Outlet Kitchen - TRV - T2

Dear Nimish Ji ,

Along with this would also require you to work on the Fresh air and Exhaust for following outlet as asked by our operations head Mr. Puneeth .

1. Malabar Express Domestic SHA T1
2. Swamy Snacks Domestic T1

Kindly guide us how do you want to take ahead so I can align the things accordingly .

Regards  
Santosh TAMBE

---

**From:** Ajit Yadav <[ajit.yadav@travelfoodservices.com](mailto:ajit.yadav@travelfoodservices.com)>

**Sent:** 18 December 2023 13:53

**To:** [nimish.shah@mepstekconsultants.com](mailto:nimish.shah@mepstekconsultants.com)

**Cc:** Shama Nair <[shama.nair@travelfoodservices.com](mailto:shama.nair@travelfoodservices.com)>; Santosh Tambe <[santosh.tambe@travelfoodservices.com](mailto:santosh.tambe@travelfoodservices.com)>; Nimisha Jadhav



<[nimisha.jadhav@travelfoodservices.com](mailto:nimisha.jadhav@travelfoodservices.com)>; Shashank Mahadik <[shashank.mahadik@travelfoodservices.com](mailto:shashank.mahadik@travelfoodservices.com)>; Saeed Khan <[saeed.khan@travelfoodservices.com](mailto:saeed.khan@travelfoodservices.com)>; Venkat Subramanian <[trivandrum.maintenance@travelfoodservices.com](mailto:trivandrum.maintenance@travelfoodservices.com)>; Puneeth Kumar <[puneeth.kumar@travelfoodservices.com](mailto:puneeth.kumar@travelfoodservices.com)>; Sindhu Thomas <[sindhu.thomas@travelfoodservices.com](mailto:sindhu.thomas@travelfoodservices.com)>; Lovejot Sekhon <[lovejot.sekhon@k-corp.in](mailto:lovejot.sekhon@k-corp.in)>; Binu Balachandran <[binu.balachandran@k-corp.in](mailto:binu.balachandran@k-corp.in)>; Stephen P <[stephen.p@k-corp.in](mailto:stephen.p@k-corp.in)>; Akshay Sharma <[akshay.sharma@semolinakitchens.com](mailto:akshay.sharma@semolinakitchens.com)>; Prakash Mistry <[prakash.mistry@travelfoodservices.com](mailto:prakash.mistry@travelfoodservices.com)>; Khushbu Verma <[khushbu.dayal@travelfoodservices.com](mailto:khushbu.dayal@travelfoodservices.com)>; Ameet Koomar <[Ameet.Koomar@adani.com](mailto:Ameet.Koomar@adani.com)>

**Subject:** RE: Request for Ducting Layout: Malabar Outlet Kitchen - TRV - T2

Dear Nimish,

Your Response is highly awaited.

Regards,  
Ajit R Yadav  
8898931514  
Travel Food Services Pvt. Ltd.  
Shiv Sagar Estate, A-Block, 1st Floor, Dr. Annie Besant Road,  
Worli, Mumbai-400018.



---

**From:** Ajit Yadav

**Sent:** 14 December 2023 05:34 PM

**To:** 'nimish.shah@mepstekconsultants.com' <[nimish.shah@mepstekconsultants.com](mailto:nimish.shah@mepstekconsultants.com)>

**Cc:** Shama Nair <[shama.nair@travelfoodservices.com](mailto:shama.nair@travelfoodservices.com)>; Santosh Tambe <[santosh.tambe@travelfoodservices.com](mailto:santosh.tambe@travelfoodservices.com)>; Nimisha Jadhav <[nimisha.jadhav@travelfoodservices.com](mailto:nimisha.jadhav@travelfoodservices.com)>; Shashank Mahadik <[shashank.mahadik@travelfoodservices.com](mailto:shashank.mahadik@travelfoodservices.com)>; Saeed Khan <[saeed.khan@travelfoodservices.com](mailto:saeed.khan@travelfoodservices.com)>; Venkat Subramanian <[trivandrum.maintenance@travelfoodservices.com](mailto:trivandrum.maintenance@travelfoodservices.com)>; Puneeth Kumar <[puneeth.kumar@travelfoodservices.com](mailto:puneeth.kumar@travelfoodservices.com)>; Sindhu Thomas <[sindhu.thomas@travelfoodservices.com](mailto:sindhu.thomas@travelfoodservices.com)>; 'Lovejot Sekhon' <[lovejot.sekhon@k-corp.in](mailto:lovejot.sekhon@k-corp.in)>; 'Binu Balachandran' <[binu.balachandran@k-corp.in](mailto:binu.balachandran@k-corp.in)>; Stephen P <[stephen.p@k-corp.in](mailto:stephen.p@k-corp.in)>; Akshay Sharma <[akshay.sharma@semolinakitchens.com](mailto:akshay.sharma@semolinakitchens.com)>; Prakash Mistry <[prakash.mistry@travelfoodservices.com](mailto:prakash.mistry@travelfoodservices.com)>; Khushbu Verma <[khushbu.dayal@travelfoodservices.com](mailto:khushbu.dayal@travelfoodservices.com)>; Ameet Koomar <[Ameet.Koomar@adani.com](mailto:Ameet.Koomar@adani.com)>

**Subject:** Request for Ducting Layout: Malabar Outlet Kitchen - TRV - T2

Dear Nimish,

Please find attached the kitchen layout for the Malabar Outlet (TRV – T2), designed by our in-house kitchen expert, Mr. Saeed Khan. The proposed location for the hood is clearly outlined in the document.

For additional reference, we have included site pictures. Should you need further clarification, feel free to reach out to Mr. Venkat (9884703317), our on-site maintenance personnel.

Kindly request your assistance in providing the ducting layout for both fresh air intake and exhaust systems.

SR.No.	Eq.No.	DESCRIPTION	MODEL NO	DIMENSIONS (Lx W x HT)	QTY	CFM
1	EH-01	SS.CROSS TYPE EXHAUST HOOD WITH FIRE SUPPRESSION SYSTEM	FABRICATED	2750 x 1150 x 600	1	3800
2	EH-02	SS.CROSS TYPE EXHAUST HOOD WITH FIRE SUPPRESSION SYSTEM	FABRICATED	3250 x 1150 x 600 (length wise in two Pcs)	1	4300

Regards,  
 Ajit R Yadav  
 8898931514  
 Travel Food Services Pvt. Ltd.  
 Shiv Sagar Estate, A-Block, 1st Floor, Dr. Annie Besant Road,  
 Worli, Mumbai-400018.

