### Trupti Dalvi

From: Irfan Sayed

Sent: 27 October 2024 12:45

To: Trupti Dalvi

Cc: Divesh Tripathi

Subject: RE: LKO-T3- Irish House Kitchen/Bond room & Idli.com - GFC's & BOQ for Safal upload - 23-10-24

Importance: High

Dear Trupti

Please find below budget for the both the outlets.

Note:- Kindly upload HVAC BOQ in Idli.com only as its common for both outlets and given same in both BOQ's.

Revert or call in case any doubt or queries.

Entity	Branch	PO Category	Cost Centre Name	Header Text	Description	Expected Delivery Date	Budget in Lacs
SKPL	Lucknow	Capex NSO	Idli.com	Interior	Interiors works	31-12-2024	28
SKPL	Lucknow	Capex NSO	Idli.com	Services	Plumbing	31-12-2024	6
SKPL	Lucknow	Capex NSO	Idli.com	Services	Electrical	31-12-2024	8
SKPL	Lucknow	Capex NSO	Idli.com	Services	HVAC & Ventilation system	31-12-2024	14
SKPL	Lucknow	Capex NSO	Idli.com	Services	Furniture/lights/DMBs etc	31-12-2024	2.2
SKPL	Lucknow	Capex NSO	Idli.com	Services	Other services such as Fire system, CCTV, Gas pipeline, suppression system, RO plant/tanks/signage's	31-12-2024	11
						<b>Grand Total</b>	69.2

Entity	Branch	PO Category	Cost Centre Name	Header Text	Description	Expected Delivery Date	Budget in lacs
SKPL	Lucknow	Capex NSO	Irish House Kitchen	Interior	Interiors works	31-12-2024	20
SKPL	Lucknow	Capex NSO	Irish House Kitchen	Services	Plumbing	31-12-2024	6
SKPL	Lucknow	Capex NSO	Irish House Kitchen	Services	Electrical	31-12-2024	4
SKPL	Lucknow	Capex NSO	Irish House Kitchen	Services	HVAC	31-12-2024	5
SKPL	Lucknow	Capex NSO	Irish House Kitchen	Services	Furniture/lights/DMBs etc	31-12-2024	1
SKPL	Lucknow	Capex NSO	Irish House Kitchen	Services	Other services such as Fire system, CCTV, Gas pipeline, suppression system, RO plant/tanks	31-12-2024	9
						Grand Total	45

Regards, Irfan Sayed +91 99676 92498 http://www.k-hospitality.com/



From: Trupti Dalvi <trupti.dalvi@travelfoodservices.com>

Sent: 25 October 2024 13:01

**To:** Irfan Sayed <irfan.sayed@travelfoodservices.com> **Cc:** Divesh Tripathi <divesh.tripathi@semolinakitchens.com>

Subject: RE: LKO-T3- Irish House Kitchen/Bond room & Idli.com - GFC's & BOQ for Safal upload - 23-10-24

Dear Irfan Sir,

Awaiting the budget

Thanks & Regards, Trupti Dalvi Project Coordinator

From: Trupti Dalvi

Sent: 23 October 2024 14:34

**To:** Irfan Sayed < <u>irfan.sayed@travelfoodservices.com</u> > **Cc:** Divesh Tripathi < <u>divesh.tripathi@semolinakitchens.com</u> >

Subject: RE: LKO-T3- Irish House Kitchen/Bond room & Idli.com - GFC's & BOQ for Safal upload - 23-10-24

Sir, please share budge for each work sheet

From: Irfan Sayed <irfan.sayed@travelfoodservices.com>

**Sent:** 23 October 2024 14:26

**To:** Trupti Dalvi < <a href="mailto:trupti.dalvi@travelfoodservices.com">trupti < <a href="mailto:trupti.dalvi@trupti.dalvi@trupti.dalvi@

Subject: FW: LKO-T3- Irish House Kitchen/Bond room & Idli.com - GFC's & BOQ for Safal upload - 23-10-24

Importance: High

Dear Trupti

Please consider attached BOQ for both.

Upload these BOQ, rest all other details are ok.

Regards, Irfan

From: Irfan Sayed <irfan.sayed@travelfoodservices.com>

**Sent:** 23 October 2024 12:22

To: Trupti Dalvi < <a href="mailto:trupti.dalvi@travelfoodservices.com">trupti Dalvi < a href="mailto:trupti.dalvi@travelfoodservices.com">trupti.dalvi@travelfoodservices.com</a>

Cc: Divesh Tripathi divesh.tripathi@semolinakitchens.com; Ravindra Kumar Singh <a href="mailto:ravindra.singh@semolinakitchens.com">ravindra.singh@semolinakitchens.com</a>; Darshan Chheda <a href="mailto:darshan.chheda@semolinakitchens.com">darshan.chheda@semolinakitchens.com</a>; Urmila Jadhav <a href="mailto:qurmila.jadhav@travelfoodservices.com">gravindra.singh@semolinakitchens.com</a>; Suraj Kumbhar <a href="mailto:qurmila.jadhav@travelfoodservices.com">ravindra.singh@semolinakitchens.com</a>; Pushpak Shewale <a href="mailto:qurmila.jadhav@travelfoodservices.com">pushpak.shewale@k-corp.in</a>; Mrunal Joshi <a href="mailto:qurmila.jadhav@travelfoodservices.com">mumila.jadhav@travelfoodservices.com</a>; Stephen P <a href="mailto:qurmila.jadhav@travelfoodservices.com">ravindra.singh@semolinakitchens.com</a>; Pushpak Shewale <a href="mailto:qurmila.jadhav@travelfoodservices.com">pushpak.shewale@k-corp.in</a>; Stephen P <a href="mailto:qurmila.jadhav@travelfoodservices.com">pushpak.shewale@k-corp.in</a>; Pushpak.shewale@k-corp.in</a>; Pushpak.shewale@k-corp.in</a>; Stephen P <a href="mailto:qurmila.jadhav@travelfoodservices.com">pushpak.shewale@k-corp.in</a>; Pushpak.shewale@k-corp.in</a>; Pushpak.shewale@k-corp.in</a>; Akshay.sharma@semolinakitchens.com</a>; Shama Nair <a href="mailto:qurmila.jadhav@travelfoodservices.com">pushpak.shewale@k-corp.in</a>; Pushpak.shewale@k-corp.in</a>; Pushpak.shewale@k-corp.in</a>; Pushpak.shewale@k-corp.in</a>; Akshay.sharma@semolinakitchens.com</a>; Shama Nair <a href="mailto:qurmila.jadhav@travelfoodservices.com">pushpak.shewale@k-corp.in</a>; Pushpak.shewale@k-corp.in</a>; Pushpak.shewale@k-corp.in</a

Subject: LKO-T3- Irish House Kitchen/Bond room & Idli.com - GFC's & BOQ for Safal upload - 23-10-24

Importance: High

Dear Trupti

Please find below link for LKO-T3- Idli.com & Irish House Kitchen & Bond Room GFC's & BOQ.

Request you to upload the same on Safal for further processing.

#### Idli.com (CI & MEP) :-

https://we.tl/t-4mMCYxlsyG

### Irish House Kitchen & Bond Room (CI & MEP):-

https://we.tl/t-sDgniIRWW3

Confirm once upload the same on Safal.

Regards, Irfan

From: GAPL <genarchpl@gmail.com>

**Sent:** 19 October 2024 18:01

To: Prakash Mistry <prakash.mistry@travelfoodservices.com>

Cc: Darshan Chheda <darshan.chheda@semolinakitchens.com>; ankit@genarch.in; Irfan Sayed <irfan.sayed@travelfoodservices.com>; Genesis Arch <navjot@genarch.in>

Subject: Re: FW: Irish House Lucknow & Idli.com

CAUTION: This email originated from outside of the organization. Do not click links or open attachments unless you recognize the sender and know the content is safe.

Hi Prakash,

Please find the attached Wetransfer Link for the Idli.com and The Irish House at Lucknow Airport GFC Set.

This includes layouts, elevations, details, coordination plans with inventories, drainage and water supply layouts, as well as HVAC, Electrical drawings and BOQ.

Note: As Discussed with you over phone call, 3D views are not updated ones regarding signage above counter. As discussed, request you to please get that signages approved as shown in 2D elevations, after which we will update the renders.

Wetransfer link: https://we.tl/t-64Yu5Vrhlx

Regards

Manpreet Singh

On Thu, Oct 17, 2024 at 6:44 PM GAPL < genarchpl@gmail.com > wrote:

Hi Prakash,

Please find the attached WeTransfer link below for the Idli.com and The Irish House at Lucknow Airport GFC set.

This includes layouts, elevations, details, coordination plans with inventories, drainage and water supply layouts, as well as HVAC and electrical drawings.

WeTransfer Link: https://we.tl/t-fJ9QusUoXu

Regards

Manpreet Singh

On Wed, Oct 16, 2024 at 5:48 PM Prakash Mistry < prakash.mistry@travelfoodservices.com > wrote:

Thanks, Darshan for your prompt reply.
Hi Ankit,
I hope all the queries have been resolved. Kindly issue the GFC by the end of today so we can begin the process of appointing vendors.
Best regards, Prakash Mistry
From: Darshan Chheda <darshan.chheda@semolinakitchens.com> Sent: 16 October 2024 17:44 To: GAPL <genarchpl@gmail.com>; Prakash Mistry <prakash.mistry@travelfoodservices.com> Cc: ankit@genarch.in; Irfan Sayed <infan.sayed@travelfoodservices.com> Subject: Re: FW: Irish House Lucknow &amp; Idli.com</infan.sayed@travelfoodservices.com></prakash.mistry@travelfoodservices.com></genarchpl@gmail.com></darshan.chheda@semolinakitchens.com>
Hii Manpreet/ Ankit,
Attached Layout with changes is good to go from our end.
Thanks & Regards,
Darshan Chheda Assistant Manager – Kitchen Design
Semolina kitchens private limited
9870189473
<u>Darshan.chheda@semolinakitchens.com</u>
From: GAPL <genarchpl@gmail.com></genarchpl@gmail.com>

From: GAPL <<u>genarchpl@gmail.com</u>> Sent: 16 October 2024 17:29

**To:** Prakash Mistry < <u>prakash.mistry@travelfoodservices.com</u>>

Cc: ankit@genarch.in <ankit@genarch.in>; Darshan Chheda &lt;<u>darshan.chheda@semolinakitchens.com</u>&gt;; Irfan Sayed &lt;<u>irfan.sayed@travelfoodservices.com</u>&gt; Subject: Re: FW: Irish House Lucknow &amp; Idli.com</ankit@genarch.in>
CAUTION: This email originated from outside of the organization. Do not click links or open attachments unless you recognize the sender and know the content is safe.
Hi Prakash,
Please find the updated layout with a larger electrical panel as required by our electrical consultant. To manage the space, we have moved the CO2 cylinder to the bond room to keep a gap between the under-counter chillers and the sunken sink cabinets.  This is as we discussed on the call with Ankit sir, Prakash, Irfan, and Darshan sir.
Please have a look and let us know how to way forward, so we will incorporate the same in GFC accordingly
Regards Manpreet Singh
On Wed, Oct 16, 2024 at 2:59 PM GAPL < genarchpl@gmail.com > wrote:
Hi Prakash,
Please find the revised equipment layout attached. Due to the electrical panel size, we've adjusted the layout to accommodate a larger panel. This change has enabled us to reduce the space between the under-counter chiller and countertop sink.
Kindly review and confirm your approval.
Best regards, Manpreet Singh
On Mon, Oct 14, 2024 at 10:30 AM GAPL < genarchpl@gmail.com > wrote:
Hi Prakash,
Please find the attached 3d render for Idli.com at T-3 Lucknow Airport.
Regards
Manpreet Singh

On Fri, Oct 4, 2024 at 2:21 PM GAPL < genarchpl@gmail.com > wrote:
Hi Prakash
Please find the attached BOQ for Idli.com & The Irish House as required,
Regards
Manpreet Singh
On Thu, Oct 3, 2024 at 11:58 AM Irfan Sayed < irfan.sayed@travelfoodservices.com > wrote:
Dear Manpreet
Only for wet work which includes Civil, brick work, plaster & water proofing with PCC on the same
Regards,
Irfan
From: Prakash Mistry < <a href="mailto:prakash.mistry@travelfoodservices.com">prakash.mistry@travelfoodservices.com</a> Sent: Thursday, October 3, 2024, 11:48 AM
To: genarchpl@gmail.com; gurvinder@genarch.in; ankit@genarch.in  Cc: Irfan Sayed < irfan.sayed@travelfoodservices.com >
Subject: FW: FW: Irish House Lucknow & Idli.com
Dear Manpreet,
Kindly share the separate BOQ for Irish House and Idli.com.
Thanks Prakash Mistry

From: GAPL <<u>genarchpl@gmail.com</u>> Sent: Tuesday, October 1, 2024 5:04 PM

To: Irfan Sayed <irfan.sayed@travelfoodservices.com>

Cc: Prakash Mistry < <a href="mailto:prakash.mistry@travelfoodservices.com">", Ankit Panday < <a href="mailto:ankit@genarch.in">", Akshay Sharma < <a href="mailto:akshay.sharma@semolinakitchens.com">", Genesis Arch < <a href="mailto:navjot@genarch.in">", Rajesh Shetty</a> <a href="mailto:rajesh.shetty@travelfoodservices.com">", Darshan Chheda <a href="mailto:darshan.chheda@semolinakitchens.com">", Divesh Tripathi@semolinakitchens.com">", Antim Sharma@semolinakitchens.com">", Antim Sharma@semolinakitchens.com<">", Antim

Subject: Re: FW: Irish House Lucknow & Idli.com

CAUTION: This email originated from outside of the organization. Do not click links or open attachments unless you recognize the sender and know the content is safe.

Hi Irfan,

Please find the attached revised drawing and boq as per feedback received in trailing email.

Please have a look and let me know if u have any queries

# D-101A Plumbing Layout:-

- RO plant to be shown with MS structure for placement. Wall Hung RO Plant
- Combi oven RO line not shown. Revised and attached
- Coffee machine required RO supply. Revised and attached
- Give one normal supply to hot Bain Marie. Updated and attached
- RO water supply required in both kitchens for drinking water near hand wash sink. Updated and attached
- Normal water supply to be given to RO plant. Already Given Please find the attached Plumbing SLD
- Hot and cold line to be given for geyser in both outlets. Already Given Please find the attached Plumbing SLD
- Plumbing points height to be mentioned in drawings. Already Given Please check the legend
- Geyser position with supply to be mentioned. Already Given Please find the attached Plumbing SLD

# A-102 Civil layout & working:-

• Raised floor details required for plumbing work. Already in Civil and WaterProofing Layout

### D-100A-Drainage layout:-

- Combi ovens drain missing. Updated and attached
- Coffee machine drain required. Updated and attached
- RO plant wastewater drain point missing. Same can be utilised for AHU drain. Updated and attached
- Hote Bain Marie drain point required. Updated and attached
- One more drain chamber to be given at drain tap off for easy access and maintenance work. Updated and attached

BOQ:-

Plumbing:-

3.02- Open grating details and qty to be rechecked. Updated and attached

Raised floor & Kota with skirting to be added in drawings & BOQ.

Drain Chambers to be added in drawings and BOQ with full finishing. Updated and attached

Gas pipeline work to be removed. **OKAY** 

RO plant to be removed from here. Need to mention in full work with proper MS platform for RO and water tank placement with pumps. Not Required Ms platform wall hung RO Plant Grease trap to be removed. OKAY

Plumbing fittings to be removed. OKAY

Gate valve to be given for main water line connections. **OKAY Updated.** 

Regards

Manpreet Singh

On Sat, Sep 28, 2024 at 3:17 PM Irfan Sayed < <u>irfan.sayed@travelfoodservices.com</u>> wrote:

Dear Manpreet

Please find attached below queries on attached drawings.

# D-101A Plumbing Layout:-

- RO plant to be shown with MS structure for placement.
- Combi oven RO line not shown.
- Coffee machine required RO supply.
- Give one normal supply to hot Bain Marie.
- RO water supply required in both kitchens for drinking water near hand wash sink.
- Normal water supply to be given to RO plant.
- Hot and cold line to be given for geyser in both outlets.
- Plumbing points height to be mentioned in drawings.
- Geyser position with supply to be mentioned.

## A-102 Civil layout & working:-

• Raised floor details required for plumbing work.

## D-100A-Drainage layout:-

- Combi ovens drain missing.
- Coffee machine drain required.
- RO plant wastewater drain point missing. Same can be utilised for AHU drain.
- Hote Bain Marie drain point required.
- One more drain chamber to be given at drain tap off for easy access and maintenance work.

### BOQ:-

Plumbing:-

3.02- Open grating details and qty to be rechecked.

Raised floor & Kota with skirting to be added in drawings & BOQ.

Drain Chambers to be added in drawings and BOQ with full finishing.

Gas pipeline work to be removed.

RO plant to be removed from here. Need to mention in full work with proper MS platform for RO and water tank placement with pumps.

Grease trap to be removed.

Plumbing fittings to be removed.

Gate valve to be given for main water line connections.

Kindly go through above points and revised the details and share for further processing.

Call in case of any queries on above points.

Regards, Irfan

From: GAPL <genarchpl@gmail.com>

Sent: Thursday, September 26, 2024, 5:43 PM

To: Prakash Mistry < prakash.mistry@travelfoodservices.com >

Cc: Ankit Panday <ankit@genarch.in>; Akshay Sharma <akshay.sharma@semolinakitchens.com>; Irfan Sayed <irfan.sayed@travelfoodservices.com>; Genesis Arch <a href="mailto:navjot@genarch.in">navjot@genarch.in</a>; Rajesh Shetty

<rajesh.shetty@travelfoodservices.com>; Darshan Chheda <darshan.chheda@semolinakitchens.com>

Subject: Re: FW: Irish House Lucknow & Idli.com

CAUTION: This email originated from outside of the organization. Do not click links or open attachments unless you recognize the sender and know the content is safe.

Hi Prakash,

Please find attached the Part GFC set for SHA Departure at Lucknow Airport, including:

- Civil layout
- Drainage and water supply layout
- Waterproofing layout
- Bill of Quantities (BOQ)

Best regards, Manpreet Singh

On Wed, Sep 25, 2024 at 1:01 PM Prakash Mistry prakash.mistry@travelfoodservices.com> wrote:

Ok, please proceed

From: GAPL < genarchpl@gmail.com >

Sent: Wednesday, September 25, 2024 12:55 PM

To: Prakash Mistry <prakash.mistry@travelfoodservices.com>

Cc: Ankit Panday <ankit@genarch.in>; Akshay Sharma <akshay.sharma@semolinakitchens.com>; Irfan Sayed <irfan.sayed@travelfoodservices.com>; Genesis Arch <navjot@genarch.in>; Rajesh Shetty

<rajesh.shetty@travelfoodservices.com>; Darshan Chheda <darshan.chheda@semolinakitchens.com>

Subject: Re: FW: Irish House Lucknow & Idli.com

CAUTION: This email originated from outside of the organization. Do not click links or open attachments unless you recognize the sender and know the content is safe.

Hi Prakash,

Updated layout is attached! We've swapped the hot water machine for a Pardeep tea kettle machine, keeping everything else the same.

Please have a look

Regards,

Manpreet Singh

On Wed, Sep 25, 2024 at 12:18 PM Ankit Panday <<u>ankit@genarch.in</u>> wrote:

Manpreet Please discuss!

### **Ankit Pandey**

Architect I Genesis Architects Pvt Ltd

Phone: +91 11 25062077-79 Mobile: +91 7827897695

Address: 371, First Floor, Rangpuri, NH48, New Delhi 110037

Web: www.genarch.in Email: ankit@genarch.in



From: Prakash Mistry < <a href="mailto:prakash.mistry@travelfoodservices.com">prakash.mistry@travelfoodservices.com</a>>

Sent: Wednesday, September 25, 2024 11:21 AM

To: Genesis Arch < navjot@genarch.in >; Genesis Arch < navjot@genarch.in >; ankit@genarch.in

 $\textbf{Cc:} \ Akshay \ Sharma < \underline{akshay.sharma@semolinakitchens.com} >; \ Shama \ Nair < \underline{shama.nair@travelfoodservices.com} >; \ Darshan \ Chheda < \underline{darshan.chheda@semolinakitchens.com} >; \ Irfan \ Sayed < \underline{chheda < \underline{darshan.chheda@semolinakitchens.com}} >; \ Akshay \ Sharma \ Chheda < \underline{darshan.chheda@semolinakitchens.com} >; \ Irfan \ Sayed < \underline{chheda < \underline{darshan.chheda@semolinakitchens.com}} >; \ Irfan \ Sayed < \underline{chheda < \underline{darshan.chheda@semolinakitchens.com}} >; \ Irfan \ Sayed < \underline{chheda < \underline{darshan.chheda@semolinakitchens.com}} >; \ Irfan \ Sayed < \underline{chheda < \underline{darshan.chheda@semolinakitchens.com}} >; \ Irfan \ Sayed < \underline{chheda < \underline{darshan.chheda@semolinakitchens.com}} >; \ Irfan \ Sayed < \underline{chheda < \underline{darshan.chheda@semolinakitchens.com}} >; \ Irfan \ Sayed < \underline{chheda < \underline{darshan.chheda@semolinakitchens.com}} >; \ Irfan \ Sayed < \underline{chheda < \underline{darshan.chheda@semolinakitchens.com}} >; \ Irfan \ Sayed < \underline{chheda < \underline{darshan.chheda@semolinakitchens.com}} >; \ Irfan \ Sayed < \underline{chheda < \underline{darshan.chheda@semolinakitchens.com}} >; \ Irfan \ Sayed < \underline{chheda < \underline{darshan.chheda@semolinakitchens.com}} >; \ Irfan \ Sayed < \underline{chheda < \underline{darshan.chheda@semolinakitchens.com}} >; \ Irfan \ Sayed < \underline{chheda < \underline{darshan.chheda@semolinakitchens.com}} >; \ Irfan \ Sayed < \underline{chheda < \underline{darshan.chheda@semolinakitchens.com}} >; \ Irfan \ Sayed < \underline{chheda < \underline{darshan.chheda@semolinakitchens.com}} >; \ Irfan \ Sayed < \underline{chheda < \underline{darshan.chheda@semolinakitchens.com}} >; \ Irfan \ Sayed < \underline{chheda < \underline{darshan.chheda@semolinakitchens.com}} >; \ Irfan \ Sayed < \underline{chheda < \underline{darshan.chheda@semolinakitchens.com}} >; \ Irfan \ Sayed < \underline{chheda < \underline{darshan.chheda@semolinakitchens.com}} >; \ Irfan \ Sayed < \underline{chheda < \underline{darshan.chheda@semolinakitchens.com}} >; \ Irfan \ Sayed < \underline{chheda < \underline{darshan.chheda@semolinakitchens.com}} >; \ Irfan \ Sayed < \underline{chheda < \underline{darshan.chheda@semolinakitchens.com}} >; \ Irfan \ Sayed < \underline{chheda < \underline{darshan.chheda < \underline{darshan.chheda@semolinakitchens.chheda < \underline{darshan.chheda < \underline{darshan.chheda <$ 

<<u>irfan.sayed@travelfoodservices.com</u>>; Rajesh Shetty <<u>rajesh.shetty@travelfoodservices.com</u>>; Saeed Khan <<u>saeed.khan@travelfoodservices.com</u>>

Subject: RE: Irish House Lucknow & Idli.com

Dear Manpreet,

Pl. replace the water boiler with Pradeep make tea machine and proceed with 3d render and GFC docket. <u>Kindly issue the wet work drawing and BOQ for Idli.com and Irish Kitchen by tomorrow.</u> And balance GFC drawing by 1st Oct.

The rest of the entire layout has been approved.

Thanks

Prakash Mistry

**From:** Saeed Khan <<u>saeed.khan@travelfoodservices.com</u>>

Sent: Wednesday, September 25, 2024 10:40 AM

To: Prakash Mistry < prakash.mistry@travelfoodservices.com>

Cc: Akshay Sharma <akshay.sharma@semolinakitchens.com>; Shama Nair <shama.nair@travelfoodservices.com>; Darshan Chheda <darshan.chheda@semolinakitchens.com>; Irfan Sayed

<irfan.sayed@travelfoodservices.com>; Rajesh Shetty <rajesh.shetty@travelfoodservices.com>

Subject: Re: Irish House Lucknow & Idli.com

In Idli .Com replace water boiler with Pradeep make Tea Machine.

Sent from Outlook for Android

From: Saeed Khan <saeed.khan@travelfoodservices.com>

Sent: Wednesday, September 25, 2024 10:35:27 AM

To: Prakash Mistry <prakash.mistry@travelfoodservices.com>

Cc: Akshay Sharma <akshay.sharma@semolinakitchens.com>; Shama Nair <shama.nair@travelfoodservices.com>; Darshan Chheda <darshan.chheda@semolinakitchens.com>; Irfan Sayed

<irfan.sayed@travelfoodservices.com>

Subject: Re: Irish House Lucknow & Idli.com

Dear Prakash,

Layout is approved by Chef Rajesh. Please go ahead.

Sent from Outlook for Android

**From:** Prakash Mistry < <u>prakash.mistry@travelfoodservices.com</u>>

Sent: Wednesday, September 25, 2024 9:56:51 AM

Cc: Aksnay Sharma < <u>aksnay.snarma@semolinakitchens.</u> <irfan.sayed@travelfoodservices.com></irfan.sayed@travelfoodservices.com>	come. Chama Nair schama nair@travalfaa daaruigaa come. Darahar Chhada sdaarhan ahlada Gaarralisalistah ara aarus Urfan Carrad
	com>; Shama Nair < <u>shama.nair@travelfoodservices.com</u> >; Darshan Chheda < <u>darshan.chheda@semolinakitchens.com</u> >; Irfan Sayed
Subject: FW: Irish House Lucknow & Idli.com	
TT' C	
Hi Saeed, pl. close Irish house and Idli.com today.	
Thanks	
Prakash	
Transfer	
From: Amit Kharkar < amit@commercialkitchendesigner	<u>s.net</u> >
Sent: Wednesday, September 25, 2024 7:40 AM	
To: Prakash Mistry < prakash.mistry@travelfoodservices	
Subject: Irish House Luckhnow	dhanashree@commercialkitchendesigners.net; komal@commercialkitchendesigners.net
Subject: Hish House Edekimow	
CAUTION: This email originated from outside of the org	anization. Do not click links or open attachments unless you recognize the sender and know the content is safe.
Hil Droke ob	
Hi! Prakash	
Hi! Prakash	
Hi! Prakash	
Hi! Prakash  Request to find attached Lucknow Irish House Serv	ice drawings along with the BOQ for your perusal.
	ice drawings along with the BOQ for your perusal.
	ice drawings along with the BOQ for your perusal.
	ice drawings along with the BOQ for your perusal.
	ice drawings along with the BOQ for your perusal.
	ice drawings along with the BOQ for your perusal.
	ice drawings along with the BOQ for your perusal.
	ice drawings along with the BOQ for your perusal.
	ice drawings along with the BOQ for your perusal.
Request to find attached Lucknow Irish House Serv	ice drawings along with the BOQ for your perusal.



**Commercial Kitchen Designers.** 



# Please consider the environment before printing this email.

The information transmitted in this e-mail and any attachments is intended only for the addressee(s) and may contain confidential or proprietary material; interception, dissemination or use of this information by others is prohibited by law. It is also the recipient's responsibility to ensure that this e-mail and any attachments are free of any virus or other defect that might negatively affect a recipient's computer system, and no responsibility is accepted by the sender for loss or damage in the event such a virus or defect exists.