35'-0"





FEEDER NO.	1	2	3	4	5	6	7	8
CABLE SIZE IN SQMM.	3C X 2.5 SQMM CU. FRLS CABLE	3C X 2.5 SQMM CU. FRLS CABLE	3C X 2.5 SQMM CU. FRLS CABLE	3C X 4 SQMM CU. FRLS CABLE	3C X 4 SQMM CU. FRLS CABLE	3C X 4 SQMM CU. FRLS CABLE	- - - - -	- - - - -
DESCRIPTION	TO LIGHTING (160W)	TO CASH COUNTER (600W)	TO DBM SCREEN (400W)	TO DBM SCREEN (400W)	TO SERVER RACK NVR (400W)	FAS PANEL (200W)	SPARE	SPARE

LOC:
8WAY TPN KPDB
C.L.: 13.50kW





GENERAL NOTES
1. THIS DRAWING IS PROPERTY OF MEPTEK CONSULTANTS
IT IS ISSUED SUBJECT TO RETURN UPON DEMAND AND IS NOT TO BE USED EXCEPT IN CONNECTION WITH THE PROJECT FOR WHICH IT IS INTEND.
2. DO NOT SCALE DRAWING. USE FIGURED DIMENSIONS ONLY.

REVISIONS

DATE	REVISION NO	DESCRIPTION

NORTH :

FINISHING CODE :

PROJECT :

SHOP NO-17 @ L-5, DELHI AIRPORT

CLIENT :

TFS

ISSUED FOR :

APPROVAL

DATE :

29.11.2023

DRAWN BY : VIJAY

CHECKED BY : RAJESH

SCALE :

NTS

TITLE:

PANELS & DB DETAILS

DRAWING NO:

MEPTEK-SBW-ELE-02

MEP CONSULTANTS :

MEPTEK CONSULTANTS
Sumer kendra, 209, opp. mahindra tower, worli, Mumabi-400018
nimish.shah@meptekconsultants.com

ARCHITECTS :-

SUBWAY
EVERSUB India Pvt Ltd
OFFICE :-
SUBWAY SYSTEMS INDIA PRIVATE LIMITED,
Awfis Space Solutions, 3rd Floor, Tower-B, Unitech Cyber Park, Grurgram, Haryana, India-122002.